Takara Leben Infrastructure Fund

May 12, 2022

For immediate release

Infrastructure Fund Issuer
Takara Leben Infrastructure Fund, Inc.
Representative: Masahide Kikuchi, Executive Director
Securities Code: 9281

Management Company
Takara Asset Management Co., Ltd.
Representative: Mamoru Takahashi, President & CEO
Contact: Masahide Kikuchi, Vice President
TEL: +81-3-6262-6402

Notice of Monthly Electricity Generation of Solar Power Generation Facilities for April 2022

Takara Leben Infrastructure Fund, Inc, hereby announces the monthly power generation of the solar power generation facilities and CO_2 Reduction under its ownership as of the end of April 2022 as follows.

【Monthly Electricity Generation and CO_2 Reduction】

Fiscal Period Ended May2022						
	Number of Solar Power Plant	Panel Output (kW)	Forecast Power Generation (kWh) (A)(Note1)	Actual Power Generation (kWh) (B)	Difference (kWh) (B)-(A)	CO_2 Reduction (kg-CO_2) (Note2)
December	42	171,538.48	11,797,431	12,318,665	+521,234	5,556,853
January	42	171,538.48	13,380,298	14,051,792	+671,495	6,350,780
February	42	171,538.48	14,911,427	15,957,496	+1,046,070	7,148,839
March	42	171,538.48	19,277,304	19,432,732	+155,427	8,746,738
April	42	171,538.48	20,728,336	20,090,654	-637,682	9,099,740
May	—	—	21,708,236	—	—	—
Total	—	—	—	—	—	—

Power generation of the entire portfolio for April 2022 had recorded 20,090,654 kWh, which is approximately 3.1% lower than the estimated electricity generation on the basis of the expected amounts of electricity generation in the 50th percentiles of probability of exceedance. The decrease in the amount of electricity generated at the LS Sakuragawa Shimoizumi is due to the fact that one of the two power conditioners has stopped generating electricity as a result of the earthquake off the coast of Fukushima Prefecture that occurred on March 16, 2022. The decrease in the amount of electricity generated at LS Sakuragawa-Nakaizumi is due to the fact that one of the two power conditioners has stopped generating electricity for safety reasons due to the theft of an electrical cable that occurred on April 19, 2022. Restoration measures are currently underway at both power plants.

(Note1) The estimated electricity generation is the total of the expected amounts of electricity generation in

the 50th percentile of probability of exceedance calculated by a third party on the basis of the database for hourly solar radiation for a year and others.

(Note2) CO_2 reduction is calculated as based on adjusted emission coefficient by electric power companies. For more details, please refer to the link (Japanese): https://ghg-santeikohyo.env.go.jp/calc

【Monthly Electricity Generation and CO2 Reduction by Power Plant】

April 2022						
No.	Name	Panel Output (kW)	Forecast Power Generation (kWh)(A) (Note)	Actual Power Generation (kWh)(B)	Difference (kWh) (B)-(A)	CO_2 Reduction (kg-CO_2)
S-01	LS Shioya	2,987.25	323,380	314,708	-8,672	138,786
S-02	LS Chikusei	1,205.67	135,685	122,500	-13,185	54,023
S-03	LS Chiba Wakabaku	705.10	73,821	70,279	-3,542	30,993
S-04	LS Miho	1,373.70	139,759	151,418	+11,659	66,775
S-05	LS Kirishima Kokubu	2,009.28	212,121	194,909	-17,212	72,116
S-06	LS Sosa	1,796.08	202,770	206,616	+3,846	91,118
S-07	LS Miyagi Osato	2,040.00	235,582	264,344	+28,762	137,723
S-08	LS Mito Takada	2,128.00	239,175	251,115	+11,940	110,742
S-09	LS Aomori Hiranai	1,820.00	221,612	265,737	+44,125	138,449
S-10	LS Tone Fukawa	2,467.08	296,415	274,385	-22,030	121,004
S-11	LS Kamisu Hasaki	1,200.00	143,375	135,089	-8,286	59,574
S-12	LS Tsukuba Bounai	2,469.60	277,849	273,871	-3,978	120,777
S-13	LS Hokota	1,913.60	212,653	238,745	+26,092	105,287
S-14	LS Nasu Nakagawa	19,800.00	2,219,245	2,159,480	-59,765	952,331
S-15	LS Fujioka A	612.00	74,071	69,657	-4,414	30,719
S-16	LS Inashiki Aranuma1	2,725.68	309,744	318,881	+9,137	140,627
S-17	LS Fujioka B	2,420.80	293,873	277,911	-15,962	122,559
S-18	LS Inashiki Aranuma2	1,200.00	144,226	147,792	+3,566	65,176
S-19	LS Sakuragawa Shimoizumi	2,535.04	326,189	149,935	-176,254	66,121

S-20	LS Fukushima Yamatsuri	1,327.36	158,182	152,315	-5,867	79,356
S-21	LS Shizuoka Omaezaki	1,098.24	128,147	125,664	-2,483	54,413
S-22	LS Mie Yokkaichi	1,984.50	215,923	211,058	-4,865	91,388
S-23	LS Sakuragawa Nakaizumi	2,698.24	333,265	234,333	-98,932	103,341
S-24	LS Shirahama	7,839.76	889,587	976,900	+87,313	310,654
S-25	LS Takahagi	1,194.60	132,939	136,268	+3,329	60,094
S-26	LS Hanno Misugidai	2,402.40	280,185	261,716	-18,469	115,417
S-27	LS Sakuragawa 1	2,545.92	319,167	288,362	-30,805	127,168
S-28	LS Sakuragawa 4	2,421.12	299,875	275,393	-24,482	121,448
S-29	LS Chiba Sammu East/West	5,059.20	589,576	562,640	-26,936	243,623
S-30	LS Nagasaki Isahaya	2,022.46	253,816	191,724	-62,092	70,938
S-31	LS Shioya 2	11,469.60	1,326,158	1,336,690	+10,532	589,480
S-32	LS Hiroshima Mihara	11,216.70	1,443,683	1,477,770	+34,087	864,495
S-33	LS Sakuragawa 2･3	5,091.84	636,283	565,043	-71,240	249,184
S-34	LS Fukushima Kagamiishi 1	712.32	87,567	82,860	-4,707	43,170
S-35	LS Fukushima Kagamiishi 2	712.32	88,385	83,682	-4,703	43,598
S-36	LS Chiba Narita	1,296.00	147,043	136,080	-10,963	60,011
S-37	LS Iwate Hirono	2,273.70	284,565	239,363	-45,202	124,708
S-38	LS Miyagi Matsushima	14,246.40	1,827,586	1,975,400	+147,814	855,348
S-39	LS Kagoshima Kanoya	1,172.08	132,240	110,687	-21,553	40,954
S-40	LS Miyagi Osato 2	2,231.10	282,018	285,644	+3,626	148,821
S-41	LS Okayama Tsuyama 1, 2 & 3	6,477.74	806,095	864,890	+58,795	505,961
S-42	LS Chiba Katsuura	30,636.00	3,984,509	3,628,800	-355,709	1,571,270
Total	—	171,538.48	20,728,336	20,090,654	-637,682	9,099,740

End

Our website: https://tif9281.co.jp/en